



LIFE SAFETY SERVICE & SUPPLY, LLC

SCOPE OF WORK - UNIT EQUIPMENT INSPECTION

UNIT EQUIPMENT IS TWO HEADED TYPE SELF CONTAINED EMERGENCY LIGHTS OR EXIT SIGNS

1. Perform simulated power outage to test unit and discharge the battery.
2. Check that lamp illumination, color, & intensity is within acceptable levels.
3. Check exit illumination on AC and emergency.
4. Check for proper operation of any options on the units.
5. Confirm proper operation of all remote emergency fixtures/heads.
6. Clean/dust all units and remote fixtures/heads.
7. Confirm recharge/charger operation.
8. Report any broken units / exit faces / wireguards.
9. Complete report and review with customer.